



Conformiteitsverklaring
Evolux

Conformiteitsverklaring

In de deze conformiteitsverklaring staan artikelnummers van de fabrikant benoemd, Hertek hanteert echter andere artikelnummers. De conformiteitsverklaring is van toepassing op de onderstaande productnummers van Hertek.

Leverancier	MULTIEVO2	C.EVOLUX2
Hertek	NED310-2	NEC310-2
	NED320-2	NEC314-2
	NED330-2	NEC320-2
	NED340-2	NEC324-2
	NED310-4	NEC330-2
	NED320-4	NEC334-2
	NED330-4	NEC340-2
	NED340-4	NEC344-2



EU DECLARATION of CONFORMITY
Ref. No.: 290A-En-2016

We: SEC, s.r.o.
Jakub a Haška 11,
949 01 NITRA, Slovakia

declare under our sole responsibility that

The product:
Maintained / non-maintained self-contained luminaire for emergency lighting
(ceiling - surface mounted / recessed with suspended safety sign)

Type:
MULTIEVO2-PP (VP)-AT.1h (3h)
MULTIEVO2-PP (VP)-ATXL.1h (3h)
MULTIEVO2-PP (VP)-ATZB.1h (3h)

Version: VP – recessed - with suspended sign; PP – surface mounting - with suspended sign;
AT – auto test; ATXL – central test; ATZB – central test – wireless

Essential technical data: 230 V; 50 Hz; 2,0 W /5,8 W; 2x20 LED 0,3 W; class I; IP 20/40;
duration 1 hour or 3 hours;

to which this declaration relates is in **conformity with** the following standards:

Low Voltage Directive: EN 60598-2-22: 2014; EN 60598-1: 2015
EN 61347-1: 2015; EN 61347-2-13: 2014
EN 61347-2-7: 2012; EN 62471: 2008

EMC Directive: EN 55015: 2013 +A1; EN 61547: 2009
including amendments

The provisions of European Directives for CE marking:
- 2014/35/EU including amendments – Low Voltage Directive
- 2014/30/EU including amendments – Electromagnetic Compatibility Directive


Manufacturer representative: Ing. Vladislav Kořenek
Position: test engineer
Place of issue: SEC, J. Haška 11, 949 01 Nitra

Date of issue: 12.12.2016

Signature and stamp:

SEC spol. s r. o.
- prevádzka -
Ul. Jakuba Haška
949 01 NITRA
-1- KRS





EU DECLARATION of CONFORMITY
Ref. No. : 290E-En-2016

We: SEC, s.r.o.
Jakub a Haška 11,
949 01 NITRA, Slovakia

declare under our sole responsibility that

The product:
Centrally supplied luminaire for emergency lighting
(ceiling / wall - surface mounted; one sided safety sign / double sided suspended safety sign)

Type:
C.EVOLUX2-P 230 V AC/DC (24 V AC/DC)
C.EVOLUX2-P ATXPR 230 V AC/DC
C.EVOLUX2-V 230 V AC/DC (24 V AC/DC)
C.EVOLUX2-V ATXPR 230 V AC/DC
C.EVOLUX2-PP 230 V AC/DC (24 V AC/DC)
C.EVOLUX2-PP ATXPR 230 V AC/DC
C.EVOLUX2-VP 230 V AC/DC (24 V AC/DC)
C.EVOLUX2-VP ATXPR 230 V AC/DC

Version: P – surface mounting; V – recessed mounting; PP – surface mounting - with double sided suspended sign; VP – recessed - with double sided suspended sign;
ATXPR – addressable central test

Essential technical data: 230 (24) V AC/DC; 5,7 W / 6,0 VA; 2x20 LED module; class I; IP20/40

to which this declaration relates is in **conformity with** the following standards:

Low Voltage Directive: EN 60598-2-22: 2014; EN 60598-1: 2015
EN 61347-1: 2015; EN 61347-2-13: 2014
EN 62471: 2008

EMC Directive: EN 55015: 2013 +A1:2015; EN 61547: 2009


The provisions of European Directives for CE marking:

- 2014/35/EU including amendments – Low Voltage Directive
- 2014/30/EU including amendments – Electromagnetic Compatibility Directive
- 2011/65/EU including amendments – RoHS2 Directive

Manufacturer representative: Ing. Vladislav Kofenek
Position: test engineer
Place of issue: SEC, J. Haška 11, 949 01 Nitra

Date of issue: 25.07.2018

Signature and stamp:
SEC spol. s r. o.
prevádzka –
Ul. Jakuba Haška
949 01 NITRA
-1- KRS





Hertek
Copernicusstraat 8
6003 DE Weert
T +31 (0)495 58 41 11
E info@hertek.nl
I www.hertek.nl

NDC017.01

Altijd een veilig idee.